ower ACU

VERTICAL PDU TO IP3

Image for reference do not scale


O/A power monitoring

O/A & per port power monitoring
O/A & per port power monitoring & per port switching
As IP3 with sequential start IP2.

IP3. IP4.

IP5. Custom configuration





Energy metrics including: Volts Watts Amps Power factor Peak Amps
 Internal Temp

Kg/Co2 K1/H

3 sets of dry contacts

Cabinet door lock

Card reader

Environmental & security metrics including:

USB port

HTTP HTTPS MOD BUS port

 SYSLOG, HTML RADIUS, SNMP v2 v3 CGI TELNET IP v4 v6

Communications & Protocols

*See product data sheet for further details

Electrical Rating.

Please note, these calculations are based on an assumed steady voltage of 230V AC and a Power Factor of 0.9. Voltage fluctuations will affect the kVA & kW values. The only rating that is constant is Current (Amps) This PDU will handle a constant current draw up to 32A. The kVA & kW ratings and are for indication purposes only.

	INPUT			ОИТРИТ				PDU TOTAL	
l	Туре	RMS Volts	RMS Amps	Туре	RMS Volts	RMS Amps	PF	kVA	kW
	1 Phase	230V	32A	1 Phase	230V	32A	0.9	7.36	6.624

Body Dimensions: 65mm wide x 55mm deep x 1288mm long

Fixing Centres: 1360mm

Material: Aluminium Extrusion / Mild Steel

Finish: Black body

3m of 3x4.0mm H07RN-F cable to 32A commando Input:

Frequency VΔ

Output: 8 x IEC C19FN (Type J) Protection: Individual fuses per outlet

Indicator: **Lead Entry Point:**

12x IEC C13FN (Type F) Power present neon per outlet bottom

Earthing: M6 Earth stud to end Rating: Standards: 32A @ 230V AC 50/60 Hz

Conforms to BS EN60950-1:2005 2nd edition +AM1 & AM2

Conforms to BS EN62368-1:2014+All:2017

UK CA: Compliant WEEE: Compliant RoHS: Compliant CE: Compliant **Operating Temp:** -10° to +55°C

5 years return to base Warranty:



Manufactured by G4 MPS Ltd.

	•	
REV:	<u> </u>	
		7 5
	M BI	ADE I
		JWG

IT-038B-IP3-3C

© 2022 This drawing and the works depicted are the copyright of and may not be reproduced or amended except by written permission. No liability will be accepted for amendments made by other persons.

Project Ref:

29/09/22